

Client: Elektro Internationaal
Order number: EL9747
Date of tests: 8 december 2011
Report code: TR

Prof. Ir. Damstra Laboratory
P.O. Box 23, 7550 AA Hengelo
Europalaan 202, 7559 SC Hengelo, The Netherlands
Tel.: +31 74 246 4351 Fax: +31 74 246 4352
www.damstra-lab.nl

Subject: EIPDU Okken panel

Purpose: To perform a temperature rise test on a functional unit inside a panel based on IEC 61439-2 Ed.1.0. 2009-01 clause 10.10.2.3.7 c) and client instruction.

Object: Eipdu (Economical Intelligent Power Distribution Unit), containing hot swappable electrical distribution groups for critical power supply, incorporated in panel type Okken-schneider electric.

Conclusion: Object passed the test.

Author: Bastiaan H. Stange

Checked by: Ing. Jan A. Otten

This report consists of:
Pages: 10

Ir. M. Binnendijk
Manager

b/a H. J. J. Seldyk

Hengelo, 1 februari 2012

The test results concern only the investigated test objects.

Publication and/or reproduction of the content of this report in any other form than by complete and verbatim text in the language it was originally issued is not allowed without written permission.

The Prof. Ir. Damstra Laboratory is the independent test institute of Eaton Electric B.V.

Client: Elektro International, de heer J. Mooij
Address: Pompmolenlaan 17, 3447 CK Woerden
Postbus 134, 3440 AC Woerden
The Netherlands

Test location: Prof. Ir. Damstra Laboratory
Hengelo, The Netherlands

Observed by: Bastiaan H. Stange

Witnessed by: R. Ritsma, Entheq Technology Group, Oldenzaal
J. Mooij, Elektro internationaal

Table of Contents

Table of Contents	2
1. Subject	3
2. Tested object	4
3. Test plan	5
4. Verification of the temperature-rise limits	5
5. Table with test results	6
6. Pictures	8